



## **STATE OF WISCONSIN**

Department of Safety and Professional Services

INDUSTRY SERVICES DIVISION

Administrator's Office

P. O. Box 2658

Madison, Wisconsin 53701-2658

**Governor Scott Walker**

**Secretary Dave Ross**

TTY: Contact Through Relay

---

### **Traps & Connections**

#### **SPS 382.32(3)(a) - 2/25/04**

**May a garbage disposal be installed on a breakroom sink?** Yes. There are no requirements prohibiting the installation of a garbage disposal on a breakroom sink.

#### **SPS 82.32(4)(b) - 6/1/06**

**Is a pedestal pedicure spa considered a pedestal fixture?** Yes. A pedestal pedicure spa may be installed in accordance with the pedestal fixture requirement for vertical distance from the fixture outlet to the trap.